



Licensed Water and Wastewater Professionals
Ben and Emily Hanner 307.690.5512
P.O. Box 775, Wilson, WY 83014
clearwateroperations@gmail.com

Squaw Creek Water District Operations Report January 2026

Water Usage

January 2026 average Gallons per Day: 11,837

January 2025 average Gallons per Day: 10,780 gallons

This number is likely lower than actual water usage due to the age of the totalizer. We recommend replacing the meter with a newer meter that can be tied into the new SCADA system.

Work Completed in January:

1/7/26: Checked infrastructure, pressures, tank levels, chlorine residual, and meters in pump house.

1/9/26: Returned old upper tank batteries to Car Quest

1/13/26: Checked infrastructure, pressures, tank levels, chlorine residual, and meters in pump house.

Collected routine bacteria sample at 1855 Porcupine Rd. Results: TC negative, E.coli negative.

1/19/26: Checked infrastructure, pressures, tank levels, chlorine residual, and meters in pump house.

Troubleshooting low amps on well 2. Pump amps checked out normal. Call to Automation Werx and they will make adjustments to programming.

1/26/26: Checked infrastructure, pressures, tank levels, chlorine residual, and meters in pump house.

1/27/26: Took pictures of contactors in well 2 panel and sent to Automation Werx for quote to replace contactors. Phone call with Ben Garcia.

Upcoming Projects:

Replace contactors on well controls or replace with VFD.

Replace totalizer meter in pump house vault with a meter that can tie into SCADA